STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF UNDERGROUNDSTORAGE TANKS
William R Snodgrass Tennessee Tower
312 Rosa L. Parks Avenue, 12th Floor
Nashville, TN 37243 (615) 532-0945

RESET FORM

IMPRESSED CURRENT CATHODIC PROTECTION SYSTEM
60-DAY RECORD OF RECTIFIER OPERATION

- This form may be utilized to document that the cathodic protection system rectifier is checked for operation at least once every 60 days, is turned on, and is continuously receiving power (rules 0400-18-01-.02(4)(c)1 and .02(4)(c)4).
- Record the output voltage, amperage, and/or the number of hours indicated on the hour meter (if equipped).
- **Any variance greater than 20% in the DC output of the rectifier (as indicated on the last cathodic protection test) should be reported to your corrosion professional so that the system can be retested and, if necessary, repairs and/or adjustments can be made.**

UST OWNER		UST FACILITY	
NAME:		NAME:	ID #:
ADDRESS:		ADDRESS:	
CITY:	STATE:	CITY:	COUNTY:

IMPRESSED CURRENT RECTIFIER DATA

Rectifier Manufacturer:	Rated DC Output: _____ VOLTS _____ AMPS
Rectifier Model:	Rectifier Serial Number:

What is the 'as designed' or lastly recommended rectifier output? _____ VOLTS _____AMPS

60-DAY LOG OF RECTIFIER OPERATION

DATE INSPECTED	RECTIFIER POWER ON?	TAP SETTINGS		DC OUTPUT		HOUR METER	CHECKED BY INITIALS	COMMENTS
		COARSE	FINE	VOLTS	AMPS			